



〈道路斜線制限検討〉
道路中心からの建物高さ：建物高さ（設計GL+8.405m）+ 道路中心高さ（設計GL-500m）= 8.905m
(1.42+5.335+1.42)×1.25 = 10.218m > 8.905m ∴OK